

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

# LISTING SERVICE

**LISTING No.** 7135-0065:121

Page 1 of 1

**CATEGORY:** Audible Signal Devices

**LISTEE:** Faraday, \*8 Fernwood Road, Florham Park, NJ 07932-1906  
Contact: \*Peter Pawchak (973) 593-2662 FAX (973) 593-6652

**DESIGN:** Models 5303, 5304, 5305, 5390 and 5395 chimes; Models 5323, 5324, 5325 horns;  
Models 5306, 5307 and 5308, followed by -A, -B, -C, -D, -N, -W or -S chime/strobes;  
Models 5326, 5327 and 5328, followed by -A, -B, -C, -D, -N, -W or -S horn/strobes.  
Models 5394, 5398, followed by -E, -G, -J, -K, -L, -M, -R, -T, -Y or -Z chime/strobes.  
Models 5394 and 5398 (without suffix) multi-candela synchronizable chime/strobes. Refer  
to listee's data sheet for detailed product description and operational considerations.

**RATING:** Electrical: 12 VDC or 21-30 VDC  
Candela: -A, -B, -N, -W :15 cd; -E, -M:15/75 cd  
-G, -R:30/75 cd; -J, -T:60/75 cd  
-C, -D, -K, -Y:75 cd; -L, -S, -Z:110 cd  
Selectable Candela: 15cd, 30cd, 75cd or 110cd  
Flash Rate: 60 flashes/minute

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and  
in a manner acceptable to the authority having jurisdiction.

**MARKING:** Listee's name or registered trademark "FOS", model number and UL label.

**APPROVAL:** Listed as audible devices for use with separately listed compatible fire alarm control units.  
Models 5303, 5304, 5305, 5306, 5307, 5308, 5390, 5394, 5395 and 5398 are for private  
mode only. Models 5323, 5324, 5325, 5326, 5327 and 5328 are for public mode. All  
units are for indoor use only except for Models 5323, 5324 and 5325 are also suitable for  
outdoor use. Models 5395 and 5398 are for ceiling mount.

If this appliance is required to produce a distinctive three-pulse Temporal Pattern Fire Alarm  
Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1999 Edition, the  
appliance must be used with a fire alarm control unit that can generate the temporal pattern  
signal. Refer to manufacturer's Installation Manual for details.

\*Rev. 06-04-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

**JUNE 18, 2004**

*Listing Expires **June 30, 2005***

Authorized By:

**DIANE K. AREND**, Senior Deputy  
Program Manager